

## ANNUAL EMISSIONS SUMMARY

MWC UNIT #: 1			COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE
			4/5/2012			
<i>Pollutant/Parameter</i>	UNITS	LIMIT	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE
Particulate Matter	mg/dscm @ 7% O <sub>2</sub>	25	0.04			
Cadmium	mg/dscm @ 7% O <sub>2</sub>	0.020	0.0002			
Lead	mg/dscm @ 7% O <sub>2</sub>	0.400	0.001			
Hydrogen Chloride - SDA Inlet	ppm <sub>v,d</sub> @ 7% O <sub>2</sub>		720			
Hydrogen Chloride - PMCD Outlet	ppm <sub>v,d</sub> @ 7% O <sub>2</sub>	29	3			
Hydrogen Chloride- Percent Removal	Percent (%)	95	99.6			
Total PCDD/PCDFs (Tetra-Octa)	ng/dscm @ 7% O <sub>2</sub>	30	2.2			
Unit Load	Klbs/hr	173	166			
PMCD Inlet Temperature	°F	340	310			
Carbon feedrate during dioxin/furan test	lbs/hr	12	12			
Fugitive Ash	Percent (%)	5	0			
Opacity	Percent (%)	10	0			

MWC UNIT #: 2			COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE
			4/5/2012			
<i>Pollutant/Parameter</i>	UNITS	LIMIT	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE
Particulate Matter	mg/dscm @ 7% O <sub>2</sub>	25	0.1			
Cadmium	mg/dscm @ 7% O <sub>2</sub>	0.020	0.0003			
Lead	mg/dscm @ 7% O <sub>2</sub>	0.400	0.002			
Hydrogen Chloride - SDA Inlet	ppm <sub>v,d</sub> @ 7% O <sub>2</sub>		764			
Hydrogen Chloride - PMCD Outlet	ppm <sub>v,d</sub> @ 7% O <sub>2</sub>	29	5			
Hydrogen Chloride- Percent Removal	Percent (%)	95	99.6			
Total PCDD/PCDFs (Tetra-Octa)	ng/dscm @ 7% O <sub>2</sub>	30	2.2			
Unit Load	Klbs/hr	173	167			
PMCD Inlet Temperature	°F	340	310			
Carbon feedrate during dioxin/furan test	lbs/hr	12	12			
Fugitive Ash	Percent (%)	5				
Opacity	Percent (%)	10	0			