

## ANNUAL EMISSIONS SUMMARY

| MWC UNIT #: <span style="border: 1px solid black; padding: 2px;">1</span> |   |       | COMPLIANCE TEST DATE | COMPLIANCE TEST DATE | COMPLIANCE TEST DATE | COMPLIANCE TEST DATE |
|---|---|-------|----------------------|----------------------|----------------------|----------------------|
|   |   |       | 1/17/2013            | 10/10/2013           |                      |                      |
| <i>Pollutant/Parameter</i>  | UNITS                                       | LIMIT | CONCENTRATION/VALUE  | CONCENTRATION/VALUE  | CONCENTRATION/VALUE  | CONCENTRATION/VALUE  |
| Particulate Matter  | <i>mg/dscm @ 7% O<sub>2</sub></i>           | 25    | 0.9                  | 0.5                  |                      |                      |
| Cadmium   | <i>mg/dscm @ 7% O<sub>2</sub></i>           | 0.020 | 0.0002               | 0.0001               |                      |                      |
| Lead  | <i>mg/dscm @ 7% O<sub>2</sub></i>           | 0.400 | 0.001                | 0.001                |                      |                      |
| Hydrogen Chloride - SDA Inlet   | <i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i> |       | 777                  | 652                  |                      |                      |
| Hydrogen Chloride - PMCD Outlet   | <i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i> | 29    | 9                    | 4                    |                      |                      |
| Hydrogen Chloride- Percent Removal  | Percent (%)                                 | 95    | 98.8                 | 99.4                 |                      |                      |
| Total PCDD/PCDFs (Tetra-Octa)   | <i>ng/dscm @ 7% O<sub>2</sub></i>           | 30    | 2.1                  | 0.2                  |                      |                      |
| Unit Load   | Klbs/hr                                     | 172   | 166                  | 165                  |                      |                      |
| PMCD Inlet Temperature  | °F  | 335   | 305                  | 305                  |                      |                      |
| Carbon feedrate during dioxin/furan test                                  | lbs/hr                                      | 12    | 12                   | 12                   |                      |                      |
| Fugitive Ash  | Percent (%)                                 | 5     | 0                    | 0                    |                      |                      |
| Opacity   | Percent (%)                                 | 10    | 0                    | 0                    |                      |                      |

| MWC UNIT #: <span style="border: 1px solid black; padding: 2px;">2</span> |   |       | COMPLIANCE TEST DATE | COMPLIANCE TEST DATE | COMPLIANCE TEST DATE | COMPLIANCE TEST DATE |
|---|---|-------|----------------------|----------------------|----------------------|----------------------|
|   |   |       | 1/17/2013            | 10/10/2013           |                      |                      |
| <i>Pollutant/Parameter</i>  | UNITS                                       | LIMIT | CONCENTRATION/VALUE  | CONCENTRATION/VALUE  | CONCENTRATION/VALUE  | CONCENTRATION/VALUE  |
| Particulate Matter  | <i>mg/dscm @ 7% O<sub>2</sub></i>           | 25    | 1.5                  | 0.8                  |                      |                      |
| Cadmium   | <i>mg/dscm @ 7% O<sub>2</sub></i>           | 0.020 | 0.0003               | 0.0002               |                      |                      |
| Lead  | <i>mg/dscm @ 7% O<sub>2</sub></i>           | 0.400 | 0.004                | 0.001                |                      |                      |
| Hydrogen Chloride - SDA Inlet   | <i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i> |       | 747                  | 610                  |                      |                      |
| Hydrogen Chloride - PMCD Outlet   | <i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i> | 29    | 7                    | 10                   |                      |                      |
| Hydrogen Chloride- Percent Removal  | Percent (%)                                 | 95    | 99.1                 | 98.4                 |                      |                      |
| Total PCDD/PCDFs (Tetra-Octa)   | <i>ng/dscm @ 7% O<sub>2</sub></i>           | 30    | 1.3                  | 0.2                  |                      |                      |
| Unit Load   | Klbs/hr                                     | 173   | 166                  | 166                  |                      |                      |
| PMCD Inlet Temperature  | °F  | 335   | 305                  | 305                  |                      |                      |
| Carbon feedrate during dioxin/furan test                                  | lbs/hr                                      | 12    | 12                   | 12                   |                      |                      |
| Fugitive Ash  | Percent (%)                                 | 5     |                      |                      |                      |                      |
| Opacity   | Percent (%)                                 | 10    | 0                    | 0                    |                      |                      |