

ANNUAL EMISSIONS SUMMARY

MWC UNIT #: 1			COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE
			4/15/2009			
Pollutant/Parameter	UNITS	LIMIT	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE
Particulate Matter	mg/dscm @ 7% O ₂	27	0.4			
Cadmium	mg/dscm @ 7% O ₂	0.020	0.0002			
Lead	mg/dscm @ 7% O ₂	0.440	0.001			
Hydrogen Chloride - SDA Inlet	ppm _{v,d} @ 7% O ₂		777			
Hydrogen Chloride - PMCD Outlet	ppm _{v,d} @ 7% O ₂	29	19			
Hydrogen Chloride- Percent Removal	Percent (%)	95	98			
Total PCDD/PCDFs (Tetra-Octa)	ng/dscm @ 7% O ₂	30	5.5			
Unit Load	Klbs/hr	183	166			
PMCD Inlet Temperature	°F	340	310			
Carbon feedrate during dioxin/furan test	lbs/hr	12	12			
Fugitive Ash	Percent (%)	5	0			
Opacity	Percent (%)	10	0			

MWC UNIT #: 2			COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE
			4/16/2009			
Pollutant/Parameter	UNITS	LIMIT	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE
Particulate Matter	mg/dscm @ 7% O ₂	27	0.7			
Cadmium	mg/dscm @ 7% O ₂	0.020	0.0003			
Lead	mg/dscm @ 7% O ₂	0.440	0.002			
Hydrogen Chloride - SDA Inlet	ppm _{v,d} @ 7% O ₂		799			
Hydrogen Chloride - PMCD Outlet	ppm _{v,d} @ 7% O ₂	29	25			
Hydrogen Chloride- Percent Removal	Percent (%)	95	97			
Total PCDD/PCDFs (Tetra-Octa)	ng/dscm @ 7% O ₂	30	10.6			
Unit Load	Klbs/hr	183	166			
PMCD Inlet Temperature	°F	341	309			
Carbon feedrate during dioxin/furan test	lbs/hr	12	12			
Fugitive Ash	Percent (%)					
Opacity	Percent (%)	10	0			