

## SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE

**COMPANY:** Wheelabrator North Andover Inc.  
**ADDRESS:** 285 Holt Road  
 North Andover, MA 01845

**IMPLEMENTING EXCLUSION OF DATA DURING STARTUP,  
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH TITLE V AIR QUALITY  
 OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

**QUARTER:** Third Quarter 2013

**PROCESS UNIT DESCRIPTION:** MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

POLLUTANT:	UNIT #1 SO <sub>2</sub> OUTLET	UNIT #1 NO <sub>x</sub>	UNIT #1 CO	UNIT #1 OPACITY
<b>REPORTING PERIOD DATES:</b>	7/1/2013		through	9/30/2013
<b>EMISSION LIMITATION:</b>	75% or 29 ppmc SO <sub>2</sub>	205 ppmc NO <sub>x</sub>	69 ppmc CO	10%
<b>MONITOR MFG. &amp; PRIMARY COMPONENTS:</b>	EcoChem MC3	EcoChem MC3	EcoChem MC3	Land MK4500II
<b>DATE OF LATEST CEMS CERTIFICATION AUDIT:</b>	December 2010	December 2010	December 2010	
<b>TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:</b>	2105.6	2105.6	2105.6	126334
<b>EMISSION DATA SUMMARY *</b>				
<b>DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:</b>				
A. STARTUP/SHUTDOWN	0	0	0	0
B. CONTROL EQUIPMENT PROBLEMS	0	0	0	0
C. PROCESS PROBLEMS	0	0	0	0
D. OTHER KNOWN CAUSES	0	0	0	0
E. UNKNOWN CAUSES	0	0	0	0
<b>TOTAL DURATION OF EXCESS EMISSION</b>	0	0	0	0
<b>TOTAL DURATION OF EXCESS EMISSION</b>	0.0%	0.0%	0.0%	0.0%
<b>TOTAL SOURCE OPERATING TIME</b>				
<b>CEMS PERFORMANCE SUMMARY</b>				
<b>CEMS DOWNTIME IN REPORTING PERIOD DUE TO:</b>				
A. MONITOR EQUIPMENT MALFUNCTIONS	0	0	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS	3	3	3	168
C. QUALITY ASSURANCE CALIBRATION	2	2	2	210
D. OTHER KNOWN CAUSES	1	1	1	90.00000001
E. UNKNOWN CAUSES	0	0	0	0
<b>TOTAL CEMS DOWNTIME</b>	6	6	6	468
<b>TOTAL CEMS DOWNTIME</b>	0.3%	0.3%	0.3%	0.37%
<b>TOTAL SOURCE OPERATING TIME</b>				
<b>DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:</b>				

\* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes