

## ANNUAL EMISSIONS SUMMARY

MWC UNIT #: 1			COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE
			7/16/2014			
Pollutant/Parameter	UNITS	LIMIT	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE
Particulate Matter	<i>mg/dscm @ 7% O<sub>2</sub></i>	25	1.6			
Cadmium	<i>mg/dscm @ 7% O<sub>2</sub></i>	0.020	0.0003			
Lead	<i>mg/dscm @ 7% O<sub>2</sub></i>	0.400	0.002			
Hydrogen Chloride - SDA Inlet	<i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i>		764			
Hydrogen Chloride - PMCD Outlet	<i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i>	29	6			
Hydrogen Chloride- Percent Removal	Percent (%)	95	99.2			
Total PCDD/PCDFs (Tetra-Octa)	<i>ng/dscm @ 7% O<sub>2</sub></i>	30	0.7			
Unit Load	Klbs/hr	183	165			
PMCD Inlet Temperature	°F	340	310			
Carbon feedrate during dioxin/furan test	lbs/hr	12	12			
Fugitive Ash	Percent (%)	5	0			
Opacity	Percent (%)	10	2.5			

MWC UNIT #: 2			COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE	COMPLIANCE TEST DATE
			7/17/2014			
Pollutant/Parameter	UNITS	LIMIT	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE	CONCENTRATION/VALUE
Particulate Matter	<i>mg/dscm @ 7% O<sub>2</sub></i>	25	0.9			
Cadmium	<i>mg/dscm @ 7% O<sub>2</sub></i>	0.020	0.0001			
Lead	<i>mg/dscm @ 7% O<sub>2</sub></i>	0.400	0.0005			
Hydrogen Chloride - SDA Inlet	<i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i>		782			
Hydrogen Chloride - PMCD Outlet	<i>ppm<sub>v,d</sub> @ 7% O<sub>2</sub></i>	29	3			
Hydrogen Chloride- Percent Removal	Percent (%)	95	99.7			
Total PCDD/PCDFs (Tetra-Octa)	<i>ng/dscm @ 7% O<sub>2</sub></i>	30	3.2			
Unit Load	Klbs/hr	183	165			
PMCD Inlet Temperature	°F	343	309			
Carbon feedrate during dioxin/furan test	lbs/hr	12	12			
Fugitive Ash	Percent (%)	5				
Opacity	Percent (%)	10	2.1			