

SEMI-ANNUAL REPORTING FOR CONTINUOUS MONITORING SYSTEMS AND STACK TESTING

MWC UNIT #	POLLUTANT or PARAMETER	START DATE mm/dd/yyyy	TIME OF EXCESS EMISSIONS		MONITORED LEVEL	APPLICABLE LIMIT	SPECIFIC REASON FOR EXCESS	CORRECTIVE ACTIONS TAKEN
			START	FINISH				
2	CO	2/8/2014	20:00	23:59	80	69	<p>PROCESS PROBLEMS: (2/8/14, 20:00 - 23:59) Upon turning the FD fan back on after cleaning the air preheater, Unit 2 experienced faster than anticipated combustion of trash that remained on the grates for the duration of the time it took to clean the air preheater. The upset resulted in elevated CO emissions for 7 minutes. A follow-up OPDR was submitted to the MADEP on 2/11/14.</p>	<p>Decrease damper position to immediately regain combustion control.</p>