

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE

COMPANY: Wheelabrator North Andover Inc.
ADDRESS: 285 Holt Road
 North Andover, MA 01845

**IMPLEMENTING EXCLUSION OF DATA DURING STARTUP,
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH TITLE V AIR QUALITY
 OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

QUARTER: Fourth Quarter 2014

PROCESS UNIT DESCRIPTION: MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

REVISION 1: 2/6/2015

POLLUTANT:	UNIT #1 SO ₂ OUTLET	UNIT #1 NO _x	UNIT #1 CO	UNIT #1 SO ₂ RE	UNIT #1 OPACITY
REPORTING PERIOD DATES:	10/1/2014		through	12/31/2014	
EMISSION LIMITATION:	75% or 29 ppmc SO ₂	205 ppmc NO _x	69 ppmc CO	75% or 29 ppmc SO ₂	10%
MONITOR MFG. & PRIMARY COMPONENTS:	EcoChem MC3	EcoChem MC3	EcoChem MC3	Western Research 721AT2	Land MK4500II
DATE OF LATEST CEMS CERTIFICATION AUDIT:	December 2010	December 2010	December 2010		
TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:	2086.7	2086.7	2086.7	2086.7	125202
EMISSION DATA SUMMARY *					
DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:					
A. STARTUP/SHUTDOWN	0	0	0	N/A	0
B. CONTROL EQUIPMENT PROBLEMS	0	0	0	N/A	0
C. PROCESS PROBLEMS	0	0	0	N/A	0
D. OTHER KNOWN CAUSES	0	0	0	N/A	0
E. UNKNOWN CAUSES	0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION	0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION	0.0%	0.0%	0.0%	N/A	0.0%
TOTAL SOURCE OPERATING TIME					
CEMS PERFORMANCE SUMMARY					
CEMS DOWNTIME IN REPORTING PERIOD DUE TO:					
A. MONITOR EQUIPMENT MALFUNCTIONS	0	0	0	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS	0	0	0	0	0
C. QUALITY ASSURANCE CALIBRATION	2	2	2	0	138
D. OTHER KNOWN CAUSES	0	0	0	31	47.99999999
E. UNKNOWN CAUSES	0	0	0	0	0
TOTAL CEMS DOWNTIME	2	2	2	31	186
TOTAL CEMS DOWNTIME	0.1%	0.1%	0.1%	1.5%	0.15%
TOTAL SOURCE OPERATING TIME					
DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:					

* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes