



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 1/24/22

Wheel Plant Wheelabrator North Andover  
Unit 1 Unit 1  
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2				CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr				
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.	4 Hr Block
1/24/2022	0	0	20.9	IF	13	IF	7	IF	29	IBF	75	IBF	0	IF		1		544		0.0		
1/24/2022	1	0	20.9	IF	13	IF	7	IF	35	IBF	79	IBF	0	IF		0		544		0.0		
1/24/2022	2	0	20.9	IF	13	IF	7	IF	28	IBF	73	IBF	0	IF		1		544		0.0		
1/24/2022	3	5	20.1	ICF	12	ICF	7	ICF	0	IBF	0	IBCF	1	ICF	0	ICF		544	544	0.0	0.0	
1/24/2022	4	13	17.2	IBCF	90	IBCF	59	IBCF	0	IBF	0	IBCF	533	IBCF		0		544		0.0		
1/24/2022	5	0	20.9	IF	10	IF	7	IF	141	IBCF	95	IBCF	0	IF		0		544		0.0		
1/24/2022	6	0	20.9	IF	9	IF	7	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	7	0	20.9	IF	8	IF	7	IF	0	IBF	0	IBF	0	IF	133	IBCF	0	0	544	544	0.0	0.0
1/24/2022	8	0	20.9	IF	8	IF	7	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	9	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	10	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	11	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF	0	IF		544	544	0.0	0.0	
1/24/2022	12	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	13	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	14	0	20.9	IF	7	IF	7	IF	0	IBF	0	IBF	0	IF		1		544		0.0		
1/24/2022	15	0	20.9	IF	7	IF	7	IF	0	IBF	0	IBF	0	IF	0	IF	0	0	544	544	0.0	0.0
1/24/2022	16	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		1		544		0.0		
1/24/2022	17	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	18	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		1		544		0.0		
1/24/2022	19	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF	0	IF	0	0	544	544	0.0	0.0
1/24/2022	20	0	20.9	IF	7	IF	6	IF	0	IBF	0	IBF	0	IF		1		544		0.0		
1/24/2022	21	0	20.9	IF	7	IF	7	IF	0	IBF	0	IBF	0	IF		1		544		0.0		
1/24/2022	22	0	20.9	IF	8	IF	7	IF	0	IBF	0	IBF	0	IF		0		544		0.0		
1/24/2022	23	0	20.9	IF	9	IF	7	IF	0	IBF	0	IBF	0	IF	0	IF	1	1	544	544	0.0	0.0

Average:  
Geometric Mean Average:

Limit:

12	IBCF
7	IBCF
≤ 205	≤ 29
24-HR Block Avg.	24-HR Geometric Mean

OR

0	IBCF
≥ 75%	Removal Efficiency

see above
≤ 69
4-HR Block Average
ppmc

see above
≤ 12
8-HR. Block Average
lb/hr

see above
≤ 345
4-HR Block Average
°F

see above
≤ 173
4-HR Block Average
klb/hr

**Status Flags**

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- \* - Shutdown



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 1/24/22

Wheel Plant Wheelabrator North Andover  
Unit 2 Unit Unit 1  
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/24/2022	0	60	9.2		160		10		40		75		1			14		310		165.6	
1/24/2022	1	60	9.4		166		11		47		76		11			14		310		165.1	
1/24/2022	2	60	9.4		171		7		33		79		3			14		310		166.3	
1/24/2022	3	60	9.1		176		2		21		89		3	4		14		310	310	165.0	165.5
1/24/2022	4	60	8.9		179		5		23		79		2			14		310		165.1	
1/24/2022	5	60	9.1		187		2		22		90		2			14		310		166.5	
1/24/2022	6	60	9.2		180		2		20		88		4			14		310		165.5	
1/24/2022	7	60	9.3		181		1		14		96		2	3		14	14	310	310	165.6	165.7
1/24/2022	8	60	9.7		164		5		19		72		2			14		310		167.0	
1/24/2022	9	60	9.3		184		5		22		75		4			14		310		165.4	
1/24/2022	10	60	9.3		186		5		18		71		4			14		310		166.0	
1/24/2022	11	60	9.4		175		6		15		63		4	3		14		310	310	165.6	166.0
1/24/2022	12	60	8.8		162		1		9		87		15			14		309		165.3	
1/24/2022	13	60	8.8		183		1		13		90		2			14		310		165.8	
1/24/2022	14	60	9.1		167		1		11		92		1			14		310		165.7	
1/24/2022	15	60	9.2		183		0		11		98		3	5		14	14	310	310	166.0	165.7
1/24/2022	16	60	9.1		179		13		45		70		3			14		310		165.9	
1/24/2022	17	60	8.9		179		2		11		83		2			14		310		166.3	
1/24/2022	18	60	8.9		183		2		11		80		2			14		310		165.8	
1/24/2022	19	60	8.9		184		2		9		74		2	2		14		310	310	166.0	166.0
1/24/2022	20	60	8.8		175		1		8		92		2			14		310		166.0	
1/24/2022	21	60	8.9		181		2		13		82		2			14		310		166.3	
1/24/2022	22	60	9.1		184		7		24		71		2			14		309		165.4	
1/24/2022	23	60	9.3		172		5		20		74		1	2		14	14	310	310	165.8	165.9

Average:  
Geometric Mean Average:

Limit:

177	3
≤ 205 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

84
≥ 75% Removal Efficiency

see above
≤ 69 ppmc 4-HR Block Average

see above
≤ 12 lb/hr 8-HR. Block Average

see above
≤ 345 °F 4-HR Block Average

see above
≤ 173 klb/hr 4-HR Block Average

**Status Flags**

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- \* - Shutdown



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 24-Jan-2022

Plant Wheelabrator North Andover  
Unit Unit 1  
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min		7-12 min		13-18 min		19-24 min		25-30 min		31-36 min		37-42 min		43-48 min		49-54 min		55-60 min		Average
0	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
1	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
2	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
3	2	IF	2	IF	2	IF	1	IF	2	IF	2	IF	2	IF	1	IF	1	IF	2	IF	2
4	2		2		2	IF	1	IF	2	IF	1	IF	1	IF	1	IF	1	IF	1	IF	1
5	1	IF	1	IF	1	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	1
6	2	ICF	23	ICF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	4
7	2	IF	2	IF	1	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	1
8	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
9	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
10	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
11	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
12	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
13	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
14	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
15	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
16	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
17	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
18	2	IF	2	IF	2	IF	2	IF	2	IF	1	IF	1	IF	2	IF	2	IF	1	IF	1
19	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
20	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
21	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
22	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2
23	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2	IF	2

**Status Flags**

I - Invalid                      C - Calibration                      F - Offline                      T - Out of Control                      ^ - Startup  
 B - Bad                            M - Maintenance                      P - Purge                      E - Excluded                      \* - Shutdown



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 24-Jan-2022

Plant Wheelabrator North Andover  
Unit Unit 2  
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	2	2	2	2	2	2	2	2	2	2	2
1	2	2	2	2	2	2	2	2	2	2	2
2	2	2	2	2	2	2	2	2	2	2	2
3	2	2	2	2	2	2	2	2	2	2	2
4	2	2	2	2	2	2	2	2	2	2	2
5	2	2	2	2	2	2	2	2	2	2	2
6	2	IBC	6	IBC	2	2	2	2	2	2	2
7	2	2	2	2	2	2	2	2	2	2	2
8	2	2	2	2	2	2	2	2	2	2	2
9	2	2	2	2	2	2	2	2	2	2	2
10	2	2	2	2	2	2	2	2	2	2	2
11	2	2	2	2	2	2	2	2	2	2	2
12	2	2	2	2	2	2	2	2	2	2	2
13	2	2	2	2	2	2	2	2	2	2	2
14	2	2	2	2	2	2	2	2	2	2	2
15	2	2	2	2	2	2	2	2	2	2	2
16	2	2	2	2	2	2	2	2	2	2	2
17	2	2	2	2	2	2	2	2	2	2	2
18	2	2	2	2	2	2	2	2	2	2	2
19	2	2	2	2	2	2	2	2	2	2	2
20	2	2	2	2	2	2	2	2	2	2	2
21	2	2	2	2	2	2	2	2	2	2	2
22	2	2	2	2	2	2	2	2	2	2	2
23	2	2	2	2	2	2	2	2	2	2	2

**Status Flags**

I - Invalid                      C - Calibration                      F - Offline                      T - Out of Control                      ^ - Startup  
 B - Bad                            M - Maintenance                      P - Purge                      E - Excluded                      \* - Shutdown