



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 1/26/23

Wheel Plant Wheelabrator North Andover
Unit 1 Unit Unit 1
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/26/2023	0	60	10.1		197		3		52		95		7			13		309		163.4	
1/26/2023	1	60	10.0		190		4		62		94		7			13		309		164.0	
1/26/2023	2	60	9.9		184		12		91		86		7			13		309		165.4	
1/26/2023	3	60	9.9		198		19		94		80		6	7		13		310	309	166.1	164.7
1/26/2023	4	60	9.9		199		12		67		82		7			13		310		165.7	
1/26/2023	5	60	10.1		199		13		57		77		6			13		309		163.6	
1/26/2023	6	60	10.0		191		7		56		88		9			13		310		163.8	
1/26/2023	7	60	10.2		195		2		43		96		8	7		13	13	309	309	164.9	164.5
1/26/2023	8	60	9.8		190		1		50		99		7			13		310		165.1	
1/26/2023	9	60	9.4		165		5		75		93		40			13		308		165.7	
1/26/2023	10	60	9.5		187		9		98		91		10			13		310		163.4	
1/26/2023	11	60	9.7		196		1		44		98		5	16		13		310	309	163.7	164.5
1/26/2023	12	60	9.6		189		1		59		98		5			13		310		164.7	
1/26/2023	13	60	9.7		191		3		66		96		5			13		309		164.8	
1/26/2023	14	60	9.7		188		1		49		99		6			13		309		161.4	
1/26/2023	15	60	9.5		179		0		41		100		30	12		14	13	310	310	163.2	163.5
1/26/2023	16	60	9.9		183		0		33		99		48			13		310		161.5	
1/26/2023	17	60	10.1		186		1		46		99		7			13		309		160.8	
1/26/2023	18	60	10.4		182		3		60		95		7			13		309		157.7	
1/26/2023	19	60	10.2		191		4		55		93		12	19		13		309	309	162.0	160.5
1/26/2023	20	60	10.3		195		0		39		99		6			13		309		159.7	
1/26/2023	21	60	10.2		193		1		48		99		8			14		310		161.2	
1/26/2023	22	60	10.3		193		0		39		99		8			13		309		159.3	
1/26/2023	23	60	10.0		182		3		64		95		9	8		13	13	309	309	156.9	159.3

Average:
Geometric Mean Average:

Limit:

189	2
≤ 205 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

97
≥ 75% Removal Efficiency

see above
≤ 69 4-HR Block Average

ppmc

see above
≥ 12 8-HR. Block Average

lb/hr

see above
≤ 345 °F 4-HR Block Average

°F

see above
≤ 173 4-HR Block Average

klb/hr

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 1/26/23

Wheel Plant Wheelabrator North Andover
Unit 2 Unit Unit 1
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/26/2023	0	60	10.3		195		0		40		99		4			13		310		168.7	
1/26/2023	1	60	10.3		195		1		45		98		5			13		310		167.5	
1/26/2023	2	60	10.2		198		0		46		99		4			14		310		166.3	
1/26/2023	3	60	10.2		190		1		53		97		5	4		13		310	310	164.8	166.8
1/26/2023	4	60	10.1		197		0		40		100		6			13		310		164.2	
1/26/2023	5	60	10.1		198		0		40		100		4			14		310		167.4	
1/26/2023	6	60	10.3		195		0		35		100		5			13		310		165.9	
1/26/2023	7	60	10.2		195		0		27		100		6	5		13	13	310	310	164.6	165.5
1/26/2023	8	60	10.4		196		0		26		100		5			14		310		164.7	
1/26/2023	9	60	10.5		197		0		38		100		4			13		310		165.3	
1/26/2023	10	60	10.4		191		1		53		98		5			14		310		164.0	
1/26/2023	11	60	10.2		196		0		29		100		4	5		13		310	310	166.5	165.1
1/26/2023	12	60	10.3		200		23		130		82		5			13		310		164.6	
1/26/2023	13	60	10.2		198		0		31		99		4			13		310		165.5	
1/26/2023	14	60	10.3		192		0		17		100		4			13		310		165.1	
1/26/2023	15	60	10.3		198		0		14		100		3	4		14	13	310	310	163.4	164.7
1/26/2023	16	60	10.3		196		0		15		100		4			13		310		165.2	
1/26/2023	17	60	10.4		198		0		16		100		4			13		310		162.0	
1/26/2023	18	60	10.3		193		0		19		100		4			13		310		161.5	
1/26/2023	19	60	10.6		198		0		18		100		4	4		13		309	310	161.4	162.5
1/26/2023	20	60	10.5		197		0		18		100		3			13		310		162.6	
1/26/2023	21	60	10.5		198		0		13		100		4			13		310		166.0	
1/26/2023	22	60	10.6		197		0		15		100		5			13		310		162.7	
1/26/2023	23	60	10.7		197		0		17		100		4	4		14	13	310	310	162.0	163.3

Average:
Geometric Mean Average:

Limit:

196	0
≤ 205 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

100
≥ 75% Removal Efficiency

see above
≤ 69 4-HR Block Average

ppmc

see above
≥ 12 8-HR. Block Average

lb/hr

see above
≤ 345 °F 4-HR Block Average

°F

see above
≤ 173 4-HR Block Average

klb/hr

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 26-Jan-2023

Plant Wheelabrator North Andover
Unit Unit 1
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	2	2	2	2	2	2	2	2	2	2	2
1	2	2	2	2	2	2	2	2	3	2	2
2	2	3	3	3	2	2	2	2	2	2	2
3	2	2	2	2	2	2	2	2	2	2	2
4	2	2	2	2	2	2	2	2	2	2	2
5	2	2	2	2	2	2	2	2	2	2	2
6	2	6	2	2	2	2	2	2	2	2	2
7	2	2	2	2	2	2	2	2	2	2	2
8	2	2	2	2	2	2	2	2	2	2	2
9	2	2	2	2	2	2	2	2	2	2	2
10	2	2	2	2	2	2	2	2	2	2	2
11	2	2	2	2	2	2	2	2	2	2	2
12	2	2	2	2	2	2	2	2	2	2	2
13	2	2	2	2	2	2	2	2	2	2	2
14	2	2	2	2	2	2	2	2	2	2	2
15	2	2	2	2	2	2	2	2	2	2	2
16	2	2	3	3	2	3	3	2	2	3	2
17	2	2	2	2	2	2	2	2	2	2	2
18	2	2	2	2	2	2	2	2	2	2	2
19	2	2	2	2	2	2	2	2	2	2	2
20	2	2	2	2	2	2	2	2	2	2	2
21	2	2	2	2	2	2	2	2	2	2	2
22	2	2	2	2	2	2	2	2	2	2	2
23	2	2	2	2	2	2	2	2	2	2	2

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 26-Jan-2023

Plant Wheelabrator North Andover
Unit Unit 2
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1
2	1	1	1	1	1	1	1	1	1	1	1
3	1	1	1	1	1	1	1	1	1	1	1
4	1	1	1	1	1	1	1	1	1	1	1
5	1	1	1	1	1	1	1	1	1	1	1
6	2	IBC	5	IBC	1	1	1	1	1	1	1
7	1	1	1	1	1	1	1	1	1	1	1
8	1	1	1	1	1	1	1	1	1	1	1
9	1	1	1	1	1	1	1	1	1	1	1
10	1	1	1	1	1	1	1	1	1	1	1
11	1	1	1	1	1	1	1	1	1	1	1
12	1	1	1	1	1	1	1	1	1	1	1
13	1	1	1	1	1	1	1	1	1	1	1
14	1	1	1	1	1	1	1	1	1	1	1
15	1	1	1	1	1	1	1	1	1	1	1
16	1	1	1	1	1	1	1	1	1	1	1
17	1	1	1	1	1	1	1	1	1	1	1
18	1	1	1	1	1	1	1	1	1	1	1
19	1	1	1	1	1	1	1	1	1	1	1
20	1	1	1	1	1	1	1	1	1	1	1
21	1	1	1	1	1	1	1	1	1	1	1
22	1	1	1	1	1	1	1	1	1	1	1
23	1	1	1	1	1	1	1	1	1	1	1

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown