



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 6/18/23

Wheel Plant Wheelabrator North Andover
Unit 1 Unit Unit 1
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr	
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block
6/18/2023	0	60	10.4		136	0	59		100		5				13		309		164.7	
6/18/2023	1	60	10.3		121	1	61		98		92				13		310		166.0	
6/18/2023	2	60	9.8		129	0	56		100		9				13		310		165.8	
6/18/2023	3	60	9.9		132	0	63		100		4	28		13		309	309	164.8	165.3	
6/18/2023	4	60	10.0		131	0	58		100		5			12		310		164.6		
6/18/2023	5	60	10.1		129	0	53		100		5			13		309		161.7		
6/18/2023	6	60	9.9		126	0	51		100		5			13		309		164.5		
6/18/2023	7	60	9.9		120	0	47		100		5	5		13	13	309	309	166.7	164.4	
6/18/2023	8	60	9.9		118	0	56		100		10			13		309		166.5		
6/18/2023	9	60	9.7		129	0	59		100		6			13		309		166.8		
6/18/2023	10	60	9.8		138	0	96		100		4			13		309		166.5		
6/18/2023	11	60	9.7		136	0	69		100		4	6		13		310	309	167.1	166.7	
6/18/2023	12	60	9.7		134	0	52		100		4			13		309		166.8		
6/18/2023	13	60	10.1		139	0	66		100		4			13		310		164.7		
6/18/2023	14	60	10.1		134	0	70		100		4			13		309		165.6		
6/18/2023	15	60	10.0		139	0	71		100		4	4		13	13	310	309	166.7	166.0	
6/18/2023	16	60	10.0		138	0	62		100		4			13		310		165.9		
6/18/2023	17	60	9.9		131	0	53		100		5			12		309		166.7		
6/18/2023	18	60	10.0		120	0	44		100		5			13		309		166.2		
6/18/2023	19	60	10.2		130	0	57		100		9	6		13		309	309	164.7	165.9	
6/18/2023	20	60	10.1		138	0	46		100		4			13		310		165.9		
6/18/2023	21	60	10.1		139	0	51		100		4			13		310		165.6		
6/18/2023	22	60	10.1		135	0	42		100		4			13		309		166.2		
6/18/2023	23	60	10.0		138	0	47		100		4	4		13	13	309	309	166.5	166.0	

Average: Geometric Mean Average:	132	0	OR	100	see above	see above	see above	see above			
Limit:	≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean		≥ 80% Removal Efficiency	≤ 69 4-HR Block Average	ppmc	≥ 12 8-HR. Block Average	lb/hr	≤ 345 °F 4-HR Block Average	≤ 173 4-HR Block Average	klb/hr

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 6/18/23

Wheel Plant Wheelabrator North Andover
Unit 2 Unit Unit 1
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
6/18/2023	0	60	12.3		139		9		64		86		1			14		310		166.4	
6/18/2023	1	60	12.3		139		6		58		90		0			13		310		167.4	
6/18/2023	2	60	12.1		140		2		52		96		1			13		310		167.2	
6/18/2023	3	60	12.3		139		7		69		90		1	I		14		310	310	166.5	166.9
6/18/2023	4	60	12.5		143		12		76		85		2			13		310		164.1	
6/18/2023	5	60	12.4		145		10		56		82		2			13		310		165.7	
6/18/2023	6	60	12.4		139		4		42		92		1			13		310		166.1	
6/18/2023	7	60	12.5		136		2		42		96		0	I		14	13	310	310	167.2	165.8
6/18/2023	8	60	12.5		144		1		40		98		1			13		310		166.9	
6/18/2023	9	60	12.4		138		3		55		95		1			13		310		165.5	
6/18/2023	10	60	12.5		140		0		43		99		1			13		310		164.8	
6/18/2023	11	60	12.4		139		2		56		96		1	I		14		310	310	167.1	166.1
6/18/2023	12	60	12.5		141		1		48		98		1			14		310		167.2	
6/18/2023	13	60	12.6		139		13		83		84		1			14		310		165.8	
6/18/2023	14	60	12.6		140		10		73		87		1			13		310		166.8	
6/18/2023	15	60	12.5		139		6		73		91		1	I		13	13	310	310	166.5	166.6
6/18/2023	16	60	12.4		140		4		73		94		1			13		310		166.5	
6/18/2023	17	60	12.4		140		3		62		96		1			13		310		166.5	
6/18/2023	18	60	12.3		139		0		56		99		1			12		310		167.0	
6/18/2023	19	60	12.4		139		1		52		99		0	I		14		310	310	166.8	166.7
6/18/2023	20	60	12.5		140		1		44		99		1			13		310		163.3	
6/18/2023	21	60	12.5		140		1		45		98		1			13		310		165.1	
6/18/2023	22	60	12.6		138		1		44		98		1			12		310		164.7	
6/18/2023	23	60	12.5		140		2		48		96		1	I		13	13	310	310	166.0	164.8

Average:
Geometric Mean Average:

Limit:

140	2
≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

96
≥ 80% Removal Efficiency

see above
≤ 69 ppmc 4-HR Block Average

see above
≥ 12 lb/hr 8-HR. Block Average

see above
≤ 345 °F 4-HR Block Average

see above
≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 18-Jun-2023

Plant Wheelabrator North Andover
Unit Unit 1
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	0	0	0	0	0	0	0	0	0	0	0
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	0	0
6	3	IC	5	IC	0	0	0	0	0	0	1
7	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	0	0	0	0	0	0	0

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 18-Jun-2023

Plant Wheelabrator North Andover
Unit Unit 2
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	4	2	2	2	2	2	2	2	2	2	2
1	2	2	2	2	2	2	2	2	2	2	2
2	2	2	2	2	2	2	2	2	2	2	2
3	2	2	2	2	2	2	2	2	2	2	2
4	2	2	2	2	2	2	2	2	2	2	2
5	2	2	2	2	2	2	2	2	2	2	2
6	3	IBC	6	IBC	2	2	2	2	2	2	2
7	2	2	2	2	2	2	2	2	2	2	2
8	2	2	2	2	2	2	2	2	2	2	2
9	2	2	2	2	2	2	2	2	2	2	2
10	2	2	2	2	2	2	2	2	2	2	2
11	2	2	2	2	2	2	2	2	2	2	2
12	2	2	2	2	2	2	2	2	2	2	2
13	2	2	2	2	2	2	2	2	2	2	2
14	2	2	2	2	2	2	2	2	2	2	2
15	2	2	2	2	2	2	2	2	2	2	2
16	2	2	2	2	2	2	2	2	2	2	2
17	2	2	2	2	2	2	2	2	2	2	2
18	2	2	2	2	2	2	2	2	2	2	2
19	2	2	2	2	2	2	2	2	2	2	2
20	2	2	2	2	2	2	2	2	2	2	2
21	2	2	2	2	2	2	2	2	2	2	2
22	2	2	2	2	2	2	2	2	2	2	2
23	2	2	2	2	2	2	2	2	2	2	2

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown