

# SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERF

**COMPANY:** Wheelabrator North Andover, Inc.  
**ADDRESS:** 285 Holt Road  
 North Andover, MA 01845

## HISTORICAL REPORTING INCLUDING STARTUP, SHUTDOWN AND MALFUNCTION EVENTS

**QUARTER:** First Quarter 2009

**PROCESS UNIT DESCRIPTION:** MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

POLLUTANT:	UNIT #2 SO <sub>2</sub> OUTFLET	UNIT #2 NO <sub>x</sub>	UNIT #2 CO	UNIT #2 OPACITY
<b>REPORTING PERIOD DATES:</b>	1/1/2009 through 3/31/2009			
<b>EMISSION LIMITATION:</b>	75% or 29 ppmc SO <sub>2</sub>	205 ppmc NO <sub>x</sub>	69 ppmc CO	10%
<b>MONITOR MFG. &amp; PRIMARY COMPONENTS:</b>	Western Research 721M	Thermo Environmental 42C	Thermo Environmental 48	Land MK4500II
<b>DATE OF LATEST CEMS CERTIFICATION AUDIT:</b>				
<b>TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:</b>	1821.2	1821.2	1821.2	109270
<b>EMISSION DATA SUMMARY *</b>				
<b>DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:</b>				
A. STARTUP/SHUTDOWN	0	0	1	0
B. CONTROL EQUIPMENT PROBLEMS	0	0	0	0
C. PROCESS PROBLEMS	0	0	0	0
D. OTHER KNOWN CAUSES	0	0	0	0
E. UNKNOWN CAUSES	0	0	0	0
<b>TOTAL DURATION OF EXCESS EMISSION</b>	0	0	1	0
<b>TOTAL DURATION OF EXCESS EMISSION TOTAL SOURCE OPERATING TIME</b>	0.0%	0.0%	0.1%	0.0%
<b>CEMS PERFORMANCE SUMMARY</b>				
<b>CEMS DOWNTIME IN REPORTING PERIOD DUE TO:</b>				
A. MONITOR EQUIPMENT MALFUNCTIONS	0	27	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS	0	26	0	0
C. QUALITY ASSURANCE CALIBRATION	0	0	0	96
D. OTHER KNOWN CAUSES	5	5	5	36
E. UNKNOWN CAUSES	0	0	0	0
<b>TOTAL CEMS DOWNTIME</b>	5	58	5	132
<b>TOTAL CEMS DOWNTIME TOTAL SOURCE OPERATING TIME</b>	0.3%	3.2%	0.3%	0.12%
<b>DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:</b>				

\* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes

# SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERF

**COMPANY:** Wheelabrator North Andover, Inc.  
**ADDRESS:** 285 Holt Road  
 North Andover, MA 01845

**IMPLEMENTING DISMISSAL AND EXCLUSION OF DATA DURING STARTUP,  
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH  
 TITLE V AIR QUALITY OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

**QUARTER:** First Quarter 2009

**PROCESS UNIT DESCRIPTION:** MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

	POLLUTANT:	UNIT #2 SO <sub>2</sub> OUTFLET	UNIT #2 NO <sub>x</sub>	UNIT #2 CO	UNIT #2 OPACITY
	<b>REPORTING PERIOD DATES:</b>	1/1/2009 through 3/31/2009			
	<b>EMISSION LIMITATION:</b>	75% or 29 ppmc SO <sub>2</sub>	205 ppmc NO <sub>x</sub>	69 ppmc CO	10%
	<b>MONITOR MFG. &amp; PRIMARY COMPONENTS:</b>	Western Research 721M	Thermo Environmental 42C	Thermo Environmental 48	Land MK4500II
	<b>DATE OF LATEST CEMS CERTIFICATION AUDIT:</b>				
	<b>TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:</b>	1821.2	1821.2	1821.2	109270
<b>EMISSION DATA SUMMARY *</b>					
<b>DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:</b>					
A. STARTUP/SHUTDOWN		0	0	0	0
B. CONTROL EQUIPMENT PROBLEMS		0	0	0	0
C. PROCESS PROBLEMS		0	0	0	0
D. OTHER KNOWN CAUSES		0	0	0	0
E. UNKNOWN CAUSES		0	0	0	0
<b>TOTAL DURATION OF EXCESS EMISSION</b>		0	0	0	0
<b>TOTAL DURATION OF EXCESS EMISSION</b>		0.0%	0.0%	0.0%	0.0%
<b>TOTAL SOURCE OPERATING TIME</b>					
<b>CEMS PERFORMANCE SUMMARY</b>					
<b>CEMS DOWNTIME IN REPORTING PERIOD DUE TO:</b>					
A. MONITOR EQUIPMENT MALFUNCTIONS		0	27	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS		0	26	0	0
C. QUALITY ASSURANCE CALIBRATION		0	0	0	96
D. OTHER KNOWN CAUSES		5	5	5	36
E. UNKNOWN CAUSES		0	0	0	0
<b>TOTAL CEMS DOWNTIME</b>		5	58	5	132
<b>TOTAL CEMS DOWNTIME</b>		0.3%	3.2%	0.3%	0.12%
<b>TOTAL SOURCE OPERATING TIME</b>					
<b>DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:</b>					

\* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes